

EMBASSY OF THE UNITED STATES OF AMERICA
REQUEST FOR QUOTATION N. 19H08020Q0012
FUEL – BULK SUPPLY AND DELIVERY FOR OBO
QUESTIONS AND ANSWERS DURING PRE-PROPOSAL CONFERENCE

- 10. Can a truck, transporting 8,000 gallons of fuel, access both points of delivery?**
Answer = Yes.
- 11. Will deliveries of fuel be requested to take place the same day at both delivery points, or will these be requested to happen on separate dates?**
Answer = Same day for both locations.
- 12. What is the position of each storage tank in reference to the ground? Are they underground, at ground level or elevated?**
Answer = Ground level.
- 13. Do you consider the need of any specific equipment to fulfill the delivery of fuel at each storage tank, e. g. pump?**
Answer = The truck has to pump the fuel to the tank, so it needs a pump in order to do this.
- 14. Does each storage tank count with a system to measure fuel at the moment of each delivery or do you request each truck to count with a system to measure each delivery?**
Answer = The truck has to count the fuel that's being delivered.
- 15. Can the date to present offers be postponed to a later date?**
Answer = Yes, upon approval from Requesting Office and then from Contracting Officer.
- 16. Who will provide the adaptor to connect the hose from the pump truck to the fuel tank, the fuel provider or the US Mission?**
Answer = The fuel provider is expected to provide the adaptor.
- 17. At the construction site, will the delivery area be leveled to give access to trucks?**
Answer = Yes, it will be leveled up for the truck to access and park.
- 18. At the construction site, what is the estimated distance from the delivery truck to the fuel tank?**
Answer = Process confirmed in Question 17 will have to take place first to be able to confirm this detail.