

## RFQ 19H08021Q0006 Questions and Answers

**Question 1: 1.** In section 9: DELIVERABLES, you are asking for 4 oil analysis, but you are listening 5 gen-sets. Does we have to include 5 oil analysis?

Deliverables Table

Checklists signed by Contractor's employee (#7.2.1)

**QTY 7**

One per equipment listed in item list after completion of each bi-monthly maintenance service

It must be noted that some line items include genset and transfer, two transfers per genset in the case of marine's house. Contractor should indicate which factory recommendation in these cases is

Oil Testing and Analysis (#9.0)

**QTY 5**

One per equipment listed in item list after completion of each annual maintenance service

There are 5 gensets contemplated

Invoice (#15)

**QTY 6**

1 for gensets and transfers after completion of each bi-monthly maintenance service COR

**Question 2: To do maintenance to the Transfer switches, we need to de-energize it, how is the procedure to ask for permission to do this?**

R- Coordinate de-energize transfer

Send e-mail to COR one week in advance of work. State the dates and amount of time system will need to be de-energized in each property. They can include this info in the same e-mail where they will need to request access for their technicians